

# Attestation

## AgBB

On the 4<sup>th</sup> of March 2024, Eurofins Product Testing A/S received a sample of a sealant with the product name:

**HIT-HY 270**

supplied by

**Hilti Entwicklungsgesellschaft mbH**

The emissions were tested according to AgBB (AgBB - Committee for Health-related Evaluation of Building Products). Sampling, testing and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 testing standards (see the test report no. 392-2024-00114301\_A\_EN).

**Evaluation of the emission test result according to AgBB:**

- The sum of VOC ("TVOC") after 3 days was in compliance with the limit of  $\leq 10$  mg/m<sup>3</sup>.
- The sum of VOC ("TVOC") after 28 days was in compliance with the limit of  $\leq 1$  mg/m<sup>3</sup>.
- The sum of SVOC after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- After 28 days the value R was calculated from the detected VOC with single concentrations above 5  $\mu$ g/m<sup>3</sup>. This value R was in compliance with the limit of  $\leq 1$ .
- The sum of VOC without LCI-value after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- The concentration of formaldehyde after 28 days was in compliance with the limit of  $\leq 0.1$  mg/m<sup>3</sup>.
- Carcinogenic substances were not detectable after 3 and after 28 days

**The tested product complies with the requirements of AgBB including the LCI-values (June 2021) for use in the indoor environment.**

23 April 2024



Henriette Buch Lauersen  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager