



88 Empire Drive • St. Paul, Minnesota • 55103  
 (651) 642-1150 • fax (651) 642-1239

## VOC Content Test Certificate

October 26, 2009

Supplier: Hilti Entwicklungsgesellschaft mbH  
 BU Chemicals  
 Hiltistrasse 6  
 86916 Kaufering  
 GERMANY

Sample Description: Hilti CP 636

Date tested: July 20, 2009

Test Method: SCAQMD method 304-91 Determination of Volatile Organic Compounds (VOC) in various materials as referenced by South Coast Air Quality Management District (SCAQMD) rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data: Legend Project Number 0903311

Specification	Product
<b>LEED 2009 (LEED 3.0)</b> <b>LEED 2.2</b> IEQ-4.1: Low-Emitting Materials – Firestop Materials	<b>Hilti</b> <b>CP 636</b>
<b>Green Building Council of Australia</b> Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
<b>Multipurpose Construction Materials;</b> <b>VOC Limit: 70 g/L</b>	<b>Product contains: &lt;1 g/L of VOC</b>

William Welbes  
*Vice President of Laboratory Operations*

Allen Noreen, Ph.D.  
*Technical Director*